

Certificate of Compliance

Certificate: 1373890

Master Contract: 217989

Project: 1373890

Date Issued: November 18, 2002

Issued to: Pyromation Incorporated
5211 Industrial Rd.
Fort Wayne IN 46825
USA
Attention: Mr. Chris Moritz

The products listed below are eligible to bear the CSA Mark shown



Issued by:


L. Candéloro

Authorized by:


Nick Altano
Operations Manager

PRODUCTS

CLASS 2258 04 - PROCESS CONTROL EQUIPMENT - Intrinsically Safe Entity - For Hazardous Locations

Class I, Division 1, Groups A, B, C, and D

Series 442, Headtransmitter, Temperature code T6 at 55 °C; Temperature code T5 at 70 °C; Temperature code T4 at 85 °C. Intrinsically safe with the following entity parameters and when installed per drawing no. M0066, $V_{max} = 30$ V, $I_{max} = 100$ mA, $C_i = 0$, $L_i = 0$.

Note: The units are certified as a component for use within an enclosure where the suitability of the final combination is to be determined by authority having jurisdiction.

APPLICABLE REQUIREMENTS

CSA Std C22.2 No. 142-M1987	-	Process Control Equipment
CAN/CSA-C22.2 No. 157-92	-	Intrinsically Safe and Non-Incendive Equipment for Use in Hazardous Locations



Certificate: 1373890
Project: 1373890

Master Contract: 217989
Date: November 18, 2002

MARKINGS

- CSA Monogram
- Submitter Identification
- Model No.
- Serial Number, Date Code or Month and Year of Manufacture
- Hazardous Location Designation
- Entity Parameters
- Temperature Code
- Maximum Ambient Temperature
- The symbol Exia
- Reference to Installation Instructions

Note: Jurisdictions in Canada may require these markings to be also in French. It is the responsibility of the Customer to provide bilingual marking, where applicable, in accordance with the requirements of the Provincial Regulatory Authorities.