



Member of the FM Global Group

FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

A-B-C. Connection Head.

NI / I / 2 / ABCD / T6, Ta = 40°C – S019701; Type 4X, IP66

NI / II / 2 / FG / T6, Ta = 40°C – S019701; Type 4X, IP66

NI / III / 1, 2 / T6, Ta = 40°C – S019701; Type 4X, IP66

A = 31A, 31B, 31C, 31D, 31E, 31Q, 34C, 34D, 34E, 91C and 91D

B = W (Only available on model 31); PS; GS; OR; HS; SB; I

C = 264-120; 341; 342; 343-2; 343-3; 343-4; 343-6; 210304; 210332; 210333; 210334; 210336; 210338;
210412; 440; 441; 442; T82

Equipment Ratings:

Non-incendive for Class I, Division 2, Groups A, B, C and D; Non-incendive for Class II, Division 2, Groups F and G; Non-incendive for Class III, Division 1 and 2 Hazardous (Classified) Locations.

FM Approved for:

Pyromation Inc
5211 Industrial Road
Fort Wayne, IN 46825 USA

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	1998
Class 3611	2004
Class 3810	2005
ANSI/NEMA 250	2003


Original Project ID: 3043144

Approval Granted: July 19, 2011

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
131115	January 15, 2019		

FM Approvals LLC



J. E. Marquedant
Group Manager, Electrical

15 January 2019
Date

To verify the availability of the Approved product, please refer to www.approvalguide.com